

MQTT Explorer

Search...



DISCONNECT



▼ 192.168.2.71

- ▶ zwave (2480 topics, 9626 messages)
- ▶ homeassistant (319 topics, 319 messages)

▼ ebusd

- ▶ global (6 topics, 518 messages)
- ▶ scan.08 (1 topic, 1 message)

▼ hmu

State = 10;342;193;8
SetMode = auto;30.5;-;-;0;1;1;0;0;0
Status01 = 29.5;27.0;-;-;-;on
LiveMonitorMain = 104;0
StatusCirPump = off
currenterror = -;-;-;-;-;

- ▶ scan.15 (1 topic, 1 message)

▼ broadcast

vdatetime = 11:22:26;25.02.2024
outsidetemp = 7.375

- ▶ scan.76 (1 topic, 1 message)

▼ ctlv2

Hc1PumpStatus = 1
z1ActualRoomTempDesired = 20
z1DayTemp = 20
z1OpMode = auto
DisplayedOutsideTemp = 7.375
z1RoomTemp = 20.1

HwcOpMode = off
HwcTempDesired = 55
Hc1FlowTemp = 31
HwcStorageTemp = -

WaterPressure = -
SystemFlowTemp = -

HwcParallelLoading = off

HwcStorageTempTop = -

HwcStorageTempBottom = -

HcStorageTempTop = -

HcStorageTempBottom = -

currenterror = -;-;-;-;-;

ContinuousHeating = -26

AdaptHeatCurve = yes

MaxCylinderChargeTime = 60

CylinderChargeHyst = 5

CylinderChargeOffset = 25

OutsideTempAvg = 6.9375

HwcHolidayStartPeriod = 01.01.2019

HwcHolidayEndPeriod = 01.01.2020

Topic



ebusd / ctlv2 / z1RoomTemp

Value



QoS: 0

02/25/2024 11:19:47 AM

20.1

▼ History

